


# Technical Review

To Advance Techniques in Acoustical, Electrical and Mechanical Measurement



## HUMAN BODY VIBRATION



**Brüel & Kjær**

**PREVIOUSLY ISSUED NUMBERS OF  
BRÜEL & KJÆR TECHNICAL REVIEW**

- 4-1981 Low Frequency Calibration of Acoustical Measurement Systems.  
Calibration and Standards. Vibration and Shock Measurements.
- 3-1981 Cepstrum Analysis
- 2-1981 Acoustic Emission Source Location in Theory and in Practice
- 1-1981 The Fundamentals of Industrial Balancing Machines and their  
Applications
- 4-1980 Selection and Use of Microphones for Engine and Aircraft  
Noise Measurements.
- 3-1980 Power Based Measurements of Sound Insulation.  
Acoustical Measurement of Auditory Tube Opening.
- 2-1980 Zoom-FFT.
- 1-1980 Luminance Contrast Measurement.
- 4-1979 Prepolarized Condenser Microphones for Measurement  
Purposes.  
Impulse Analysis using a Real-Time Digital Filter Analyzer.
- 3-1979 The Rationale of Dynamic Balancing by Vibration  
Measurements.  
Interfacing Level Recorder Type 2306 to a Digital Computer.
- 2-1979 Acoustic Emission.
- 1-1979 The Discrete Fourier Transform and FFT Analyzers.
- 4-1978 Reverberation Process at Low Frequencies.
- 3-1978 The Enigma of Sound Power Measurements at Low  
Frequencies.
- 2-1978 The Application of the Narrow Band Spectrum Analyzer Type  
2031 to the Analysis of Transient and Cyclic Phenomena.  
Measurement of Effective Bandwidth of Filters.
- 1-1978 Digital Filters and FFT Technique in Real-time Analysis.
- 4-1977 General Accuracy of Sound Level Meter Measurements.  
Low Impedance Microphone Calibrator and its Advantages.
- 3-1977 Condenser Microphones used as Sound Sources.
- 2-1977 Automated Measurements of Reverberation Time using the  
Digital Frequency Analyzer Type 2131.  
Measurement of Elastic Modulus and Loss Factor of PVC at  
High Frequencies.
- 1-1977 Digital Filters in Acoustic Analysis Systems.  
An Objective Comparison of Analog and Digital Methods of  
Real Time Frequency Analysis.

*(Continued on cover page 3)*

# TECHNICAL REVIEW

No. 1 — 1982

# Contents

<b>Human Body Vibration Exposure and its Measurement</b> by G. Rasmussen .....	3
<b>News from the Factory</b> .....	32

# HUMAN BODY VIBRATION EXPOSURE AND ITS MEASUREMENT

by

*G.Rasmussen*

## **ABSTRACT**

Experimental data collected over the years, for defining limits of vibration exposure to human beings, have resulted in a set of vibration criteria specified in ISO Standard 2631. In this article, instrumentation requirements for evaluation of the responses of humans to vibration according to these criteria are described, as well as some of the pitfalls to be avoided during these measurements.

Exposure limits for vibration transmitted to the hands and arms of operators of vibrating tools have been suggested in Draft Standard ISO/DIS 5349. A special hand adaptor developed for the measurement of hand-arm vibration transmitted from the handle of such tools is described in the article, and measurement results obtained with it on a chip hammer are illustrated.

## **SOMMAIRE**

Les données expérimentales recueillies au cours des années pour définir les limites d'exposition des personnes aux vibrations ont abouti à l'établissement d'une série de facteurs de vibration donnés dans la norme ISO 2631. L'instrumentation requise pour évaluer la réponse des personnes aux vibrations suivant ces facteurs est décrite dans cet article, ainsi que quelques pièges à éviter pendant les mesures.

Les limites d'exposition aux vibrations transmises aux mains et aux bras des utilisateurs d'outils vibrants sont suggérées dans la Proposition de norme ISO/DIS 5349. Un adaptateur spécial développé pour la mesure des vibrations transmises par la poignée de ces outils est décrit dans cet article. Les résultats des mesures obtenus avec cet adaptateur sur un petit marteau piqueur sont illustrés.

## ZUSAMMENFASSUNG

Über Jahre hinweg gesammelte empirische Daten wurden zu Grunde gelegt, um Grenzwerte für Schwingungen, denen der Mensch ausgesetzt wird, festzulegen, und sind in ISO 2631 spezifiziert. In diesem Artikel werden Aufbauten beschrieben, mit denen sich Messungen nach diesen Kriterien durchführen lassen, sowie einige Fehlerquellen, die bei diesen Messungen umgangen werden müssen. Im Entwurf ISO/DIS 5349 werden Grenzwerte für Schwingungen, die über Hand und Arm durch vibrierende Maschinen übertragen werden, vorgeschlagen. Es wird ein spezieller Handadapter beschrieben, der zur Messung solcher Hand/Arm-Schwingungen, übertragen von handgehaltenen Maschinen, entwickelt wurde. Meßergebnisse von einem Presslufthammer werden gezeigt.

### Introduction

The human body is both physically and biologically a "system" of an extremely complex nature. When looked upon as a mechanical system it can be considered to contain a number of linear as well as non-linear "elements", and the mechanical properties are quite different from person to person.

Biologically the situation is by no means simpler, especially when psychological effects are included. In considering the response of man to vibrations and shocks it is necessary, however, to take into account both mechanical and psychological effects.

Knowledge about comfort and fatigue-decreased proficiency is based on statistical data collected under practical and experimental conditions. Because experiments with human beings are difficult, time-consuming and in extreme cases unesthetical, much of the knowledge about damaging effects has been obtained from experiments on animals. It is, of course, not always possible to "scale" results obtained from animal experiments to reactions expected from man, but nevertheless such experiments often result in valuable information.

Considering first the human body as a mechanical system it may, at low frequencies and low vibration levels, be roughly approximated by a linear lumped parameter system of the type shown in Fig. 1. One of the most important parts of this system with respect to vibration and shock effect seems to be the part marked "thorax-abdomen system". This is due to a distinct resonance effect occurring in the 3-6 Hz range as indicated on Fig. 2 and 3 and which makes efficient vibration isolation of a sitting or standing person very difficult. A further resonance effect




Fig. 1. Simplified mechanical system representing the human body standing on a vertically vibrating platform

is found in the 20 to 30 Hz region and is caused by the head-neck-shoulder system, Fig. 3.




Fig. 2. Transmissibility of vertical vibration from table to various parts of the body of a standing human subject as a function of frequency


Also in the region 60 to 90 Hz disturbances are felt which suggest eyeball resonances, and a resonance effect in the lower jaw-skull system has been found between 100 and 200 Hz.

Above 100 Hz, simple lumped parameter models like that shown in Fig. 1 are not very useful. It is then necessary to apply continuous structural analysis methods which become very complex. By such methods, however, it has been shown that for the skull itself, the fundamental mode of vibration seems to be in the region of 300 – 400 Hz with resonances for higher modes around 600 to 900 Hz. At still higher frequencies use must be made of wave theory both in the form of shear waves and of compressional waves (sound waves).

From a shock and vibration point of view the low frequency range may be considered most important. Some very interesting measurements have here been made by von Békésy and concern the attenuation of vibration along the human body. The results obtained at 50 Hz are reproduced in Fig. 4 and show that the attenuation from foot to head is



of the order of 30 dB. Similarly, the attenuation from hand to head is roughly 40 dB.



270159

Fig. 3. Transmissibility of vertical vibration from table to various parts of a seated human subject as a function of frequency




Fig. 4. Attenuation of vibration at 50 Hz along human body. The attenuation is expressed in decibels below values at the point of excitation. For excitation of (A) hand, and (B) platform on which subject stands

### Vibration Exposure Criteria

Apart from the mechanical responses mentioned above, both physiological and psychological effects are observed. Although these effects are rather complex and difficult to measure, it seems that physiological results obtained from animal experiments also apply to man to a certain extent. These experiments have been mostly concerned with changes in food assimilation, muscular activity, reproductive activity etc. as well as actual internal injury.

Psychological effects such as perception, discomfort, and pain, have recently been studied in some detail. Most of the studies have been carried out on vehicle drivers and aircraft pilots, whose ability to perform complex tasks under adverse environmental conditions, including vibration, is particularly important. The data available is therefore mainly for sitting or standing subjects. The recent ISO 2631 - 1978




Fig. 5. Vertical vibration exposure criteria curves defining equal fatigue-decreased proficiency boundaries

standard brings this data conveniently together as a set of vibration criteria curves for vertical and lateral vibration over the frequency range 1 to 80 Hz. These are shown in Figs.5 (vertical) and 6 (lateral), and apply to vibration transmitted to the torso of a standing or sitting person in the axis system indicated.

Vibration at frequencies below 1 Hz occurs in many forms of transport and produces effects, e.g. Kinetosis (motion sickness), which are completely different in character from those produced at higher frequencies. These effects cannot be simply related to the three parameters of the exciting motion, intensity, duration, and frequency, as has been possible in the range from 1 Hz to 80 Hz. In addition, human reaction to vibration below 1 Hz is extremely variable and seems to depend on a large number of external factors which have nothing to do with the motion, e.g. age, sex, vision, activity, odours. Despite this variability and the limited amount of data available, an attempt has been made to




Fig. 6. Lateral vibration exposure criteria curves defining equal fatigue-decreased proficiency boundaries

formulate tentative standards for the frequency range from 1 Hz down to 0,1 Hz in an addendum to the previously mentioned Standard for whole-body vibration i.e. ISO 2631.

Above 80 Hz, the sensations and effects are very dependent upon local conditions at the point of application, e.g. the actual direction, position and area over which the vibration is transmitted, and upon the damping at this point, e.g. due to clothing or footwear. These external factors heavily influence the response of the skin and superficial tissue chiefly affected by frequencies above 80 Hz. It is thus generally not possible at present to state valid criteria outside the stated range, 1 Hz to 80 Hz.




Fig. 7. Tolerance of human subjects in the standing or supine position to repetitive vertical impact pulses representative of impacts from pile drivers, heavy tools, heavy traffic etc. Subjective reaction is plotted as a function of the maximum displacement of the initial pulse and its rise time. The numbers indicate the following reactions for the areas between the lines: I a, threshold of perception; I b, for easy perception; I c, of strong perception, annoying; II a, very unpleasant, potential danger for long exposures; II b, extremely unpleasant, definitely dangerous. The decay process of the impact pulses was found to be of little practical significance

The vibration levels indicated by the curves in Figs.5 and 6 are given in terms of RMS acceleration levels which produce equal fatigue-decreased proficiency. Exceeding the exposure specified by the curves will, in most situations cause noticeable fatigue and decreased job proficiency in most tasks. The degree of task interference depends on the subject and the complexity of the task but the curves indicate the general range for onset of such interference and the time dependency observed.

An upper bound to exposure considered acceptable (hazard to health as well as performance) is taken to be twice as high as (6 dB above) the "fatigue-decreased proficiency" boundary shown in Fig. 5 while the "reduced comfort boundary" is assumed to be about one third of (10 dB below) the stated levels.

These criteria are presented as recommended guidelines or trend curves rather than firm boundaries classifying quantitative biological or psychological limits. They are intended only for situations involving healthy, normal people considered fit for normal living routines and the stress of an average working day.

There are, as yet, no firm criteria for purely angular vibration equivalent to those for purely translational vibration as described above. In practice, angular motion (i.e. in yaw, roll and pitch) whose centres of rotation lie at a distance from the point of application to the body, can be adequately approximated by purely translatory motion. However, there is much current work aimed at the eventual definition of criteria curves similar to those of Figs.5 and 6 for translatory vibration.

Finally, Fig. 7 indicates the tolerance of human subjects to single shock acceleration pulses of the type produced in the floor near drop forges or similar equipment (results from a single study).

Symptoms for vibration exposure at frequencies of 1 to 20 Hz are shown in Table 1. The frequency ranges given are those where the symptoms are most predominant.

Symptoms	Frequency
General feeling of discomfort	4-9
Head symptoms	13-20
Lower jaw symptoms	6-8
Influence on speech	13-20
"Lump in the throat"	12-16
Chest pains	5-7
Abdominal pains	4-10
Urge to urinate	10-18
Increased muscle tone	13-20
Influence on breathing movements	4-8
Muscle contractions	4-9

820009

Table 1.

### Hand-arm Vibration Exposure Criteria

Hand-arm vibration is the second large problem area where transmission into the human body is concerned. It is, however, rather different from whole-body vibration in the type of problems to which it gives rise. Whereas vibration transmitted into the standing or seated body normally gives rise to problems of a general nature, e.g. motion sickness, discomfort, reduced-working efficiency, etc., vibration applied to the hand-arm may, in addition, produce actual physical damage locally if the level and exposure times are sufficiently high.

Vibration levels encountered in many commonly used power tools are sufficiently high to cause damage when operated for durations common in industry. Typical of these power tools are chipping hammers, power grinders, hammer drills, and chain saws, found in widespread use in the mining, construction, manufacturing and forestry industries. Vibration may be transmitted into the body from a vibrating tool or hand-held workpiece via one or both arms simultaneously, causing, at lower levels, discomfort and reduced working efficiency. At higher levels and longer exposure periods, diseases affecting the blood vessels, joints and circulation occur. Severe exposure leads to a progressive circulation disorder in the part of the body suffering the highest level of vibration, usually the fingers or hand where hand-held tools are concerned. This is variously known as "dead hand", vibration-induced white finger, or Raynaud's disease. In extreme cases this leads to permanent damage or gangrene. These diseases and their causes are currently being extensively investigated both by medical and engineering researchers.





Fig. 8. a) Exposure guidelines for vibration transmitted to the hand  
 b) Time Exposure versus overall weighted acceleration



A very recent ISO draft proposal (5349) attempts to gather current knowledge into a convenient form and to enable conclusions to be drawn about the damage risk of practically measured vibration exposures. The suggested guideline levels are shown in Fig. 8.a) and cover the frequency range from 8 Hz to 1 kHz. Although exposure curves for both third octave and octave bands are presented, third octaves are recommended as these are likely to be more stringent than octaves when applied to the discrete frequency spectra often encountered in rotating hand-held tools. It should be noted that the current trend is to recommend the use of standardized 1/3 octave filter analysis especially in research. Practical regulatory measurements are recently recommended to be carried out using overall weighting for one figure reading as shown later in this article. Overall weighted acceleration versus time exposure relationship is shown in Fig.8.b) according to A.J.Brammer, NRC, Canada.

Most of the data used to derive the curves were from pure sine or narrow band investigations and they are therefore mainly applicable to that type of excitation. However, they may be provisionally applied to repeated shock and other types of markedly non-sinusoidal excitation, in which case a measure of the crest factor should be determined.

### **Measurement of Human Vibration**

Techniques for measuring vibration exposure have for many years been less coordinated than desirable. The data presented sometimes lack proper description of the instrumentation used to acquire it and of the important instrumentation characteristics. The descriptors used to characterize a signal are very important.

Possible descriptors, (Fig. 9) which may all be seen used in the current literature, are:

- positive peak
- negative peak
- maximum peak
- peak – peak
- peak level (bandwidth limited)
- max. r.m.s. level (bandwidth and time constant required)
- $L_{eq}$  time (bandwidth limited) (time required)
- 60 sec  $L_{eq}$  (bandwidth limited)
- max. r.m.s. 125 m/sec
- max. r.m.s. 1 sec




Fig. 9. Signal Detection

$$\text{crest factor} = \frac{\text{peak}}{\text{r.m.s.}} \quad (\text{not defined})$$

$$\text{crest factor} = \frac{\text{peak level}}{60 \text{ sec } L_{eq}}$$

$$\text{Kurtosis} = \frac{\int_{-\infty}^{\infty} (x - \bar{x})^4 P(x) dx}{\sigma^4}$$

$$L_{eq} \text{ dose in \%} \quad L_{eq} = 10 \log \frac{1}{T} \int_0^T \left( \frac{a(t)}{10^{-6}} \right)^2 dt$$

where  $L_{eq}$  is in dB re.  $10^{-6} \text{ ms}^{-2}$  and  $a(t)$  is frequency weighted acceleration in  $\text{ms}^{-2}$ .

Basically, vibration of man is measured in acceleration units  $\text{m/s}^2$  r.m.s. of a 1/3 octave frequency band (or possibly 1 octave bands for hand-arm vibration) over the frequency range of interest. The level of vibration may also be quoted in logarithmic units in terms of dB re  $1 \mu\text{m/s}^2$ .




Fig. 10. Response of frequency-weighting filters

This logarithmic representation of amplitudes is particularly useful for quoting overall weighted levels, where any resemblance with the  $m/s^2$  is lost due to the weighting. The standards for Measurement of Human Vibration for instance ISO 2631 – 1978 take the relationship between time versus level into consideration. It thus gives exposure levels or doses in percent of permitted vibration exposure for up to 24 hours. This makes the use of an overall weighting important when single figure values are required for regulatory purposes (see Fig. 10).

The weighted vibration level is expressed in “Weighted  $m/s^2$ ” or in decibels (dB). The weighted vibration level in decibels is 20 times the logarithm to the base ten of the ratio of a weighted acceleration to the reference acceleration. Or mathematically the acceleration is weighted in accordance with one of the four frequency weightings 0,1 – 0,63 Hz, 1 – 80 Hz (Whole Body, X and Y directions), 1 – 80 Hz (Whole Body, Z direction), 8 – 1000 Hz (Hand-Arm, all directions), and is time-weighted using RC time constants of 8 – 1 s, or linear integration of 60 s, or Peak. The reference acceleration is  $1 \mu m/s^2$ . When quoting the weighted acceleration level, the frequency weighting and linear or exponential time weighting employed for the measurements must be indicated. In vibration measurements it is often desirable to measure in more than one axis. For continuous or very repetitive signals, consecutive measurements of the x, y and z axis may be carried out and the maximum r.m.s. weighted acceleration “ $A_w$ ” obtained from

$$A_w = \sqrt{A_{wx}^2 + A_{wy}^2 + A_{wz}^2}$$

Using this calculation will result in a conservative evaluation giving the maximum value which may occur. The minimum value will be represented by the largest single axis value measured. The use of 60 s. linear integrated r.m.s. detection is recommended. Alternatively, the maximum r.m.s. obtained in a specified time interval using 1 s time integration. The 1 s RC time constant should be reported as this will significantly affect the measured results when measuring signals with large crest factors. In principle, a human response vibration meter may contain the choice of signal processing and read-out, shown in Fig. 11.




Fig. 11. Signal processing and read-out choices





Fig. 12. Simplified schematic block diagram of the Human-Response Vibration Meter

An instrument developed for measurements according to these criteria, is the B & K Human-Response Vibration Meter Type 2512, the block diagram of which is also shown in Fig. 12. For more research-oriented work, it is often important to obtain more detailed information about the frequency content of the vibration being measured using filter techniques. The use of sequential switching requires a steady signal over a rather long time and is therefore time consuming and sometimes not well suited for the fluctuations we often see in vibrations influencing man. Parallel analog filter bands have shortcomings in the detector response and often misjudge rapidly varying signals.

FFT (Fast Fourier Transform) processors analyse blocks of data. It is important to realize that the block of data represents an approximation if a continuous, variable signal is analysed. Also the ultimate synthesis into 1/3 or 1/1 octaves often contains serious errors due to approximations, and the use of Hanning or other time-varying functions will make real-time data collection impossible. Accurate and non-comprising filter and detector techniques can be realized in the digital filter, which allows continuous data collection at very fast rates with no loss of integration time – linear or exponential – with a chosen confidence level.




Fig. 13. a) Octave filter characteristic  
 b) 1/3 octave filter characteristic

The use of the power spectrum through 1/3 octave standardized filters which fulfil IEC 225 – 1966, DIN 45 652 and ANSI S1.11 – 1966 standards ensures easy comparison of spectra (see Fig. 13).

Vibration data in relation to influence on man is most conveniently reported on log-log scales while technical data may sometimes be most useful in log-log or log-lin or lin-lin scales. (See Figs.14 and 15).




Fig. 14. Linear and logarithmic amplitude scales. Presentation of same signal on log-lin and lin-lin scales

Transducer technology is in general less of a problem when we deal with whole-body measurements. The main rule being that measurements take place at the point of application to the body. A useful guide may be found in ISO DP 5348 for mounting of seismic pickups. Also a “seat transducer” consisting of a deformable pad which follows the seat contour and containing a triaxial accelerometer for simultaneous measurements in three mutually perpendicular axes of vibration is well standardized (SAE Recommended Practice J 1013 (1973)) and will cover most whole-body measurement situations. (See Fig. 16).




Fig. 15. Example of use of log-lin and log-log scale

Measurements according to ISO 2631 and DAM 1 as well as DAD 1 present no special instrumentation problems when proper transducer technology is chosen. In particular, one should ensure minimum base bending, cable whip, and temperature gradient sensitivity. This is even more critical in carrying out measurements in the very low frequency range, popularly referred to as "Motion Sickness", dealt with in ISO 2631 DAD 2. A four channel FM (Frequency Modulated) tape recorder is normally used for simultaneous recording of three-axis vibration ensuring better than 3,5% reproduction accuracy as also required for mea-




Fig. 16. Whole-Body Seat Transducer sectional view



surements on agricultural vehicles, and enabling frequency transformation of 1:10 for analysis by recording and replaying the signal at different speeds.

### Hand-Arm Vibration Measurements

The measurement of Hand-Arm Vibration presents some special problems both with regard to instrumentation and transducer techniques.

Basically, 1/3 octave or 1/1 octave filtered signal levels are quoted in the relevant Draft standard. However, it is also common practice to use overall weighting filters for single number readings.

The overall weighting method has become the primary method of quoting hand-arm vibration levels for regulatory purposes, industrial hygiene applications, and single number readings for labelling of hand tools. (See Fig. 17)

The 1/3 octave analysis method is still to be preferred for gathering data in research and practical engineering hand-arm vibration control





Fig. 17. Hand-Arm weighting filter characteristics

work where high resolution of the frequency spectrum is required. The most common error in quoting 1/3 or 1/1 octave levels is introduced using results obtained from FFT analyzers. Harmonic signals or well defined random noise may very well be treated by the calculation of a block sample with good approximation to the continuous sampling technique, and the measurement of one single transient like a hammer blow is also well suited for FFT calculation. But series of transients or time varying signals like those most often dealt with on percussive tools - chain saws - pedestal grinders etc., are very difficult to assess without error even using averaging over many samples. Errors in the power spectrum at high frequencies may easily be introduced through limited block sample length.

Gathering data in the field for research purposes is most conveniently carried out using portable instrumentation with instrumentation tape recorders for subsequent laboratory examination. (See Fig. 18)



*Fig. 18. Fully portable instrumentation for field measurements*

The introduction of errors due to the very high acceleration levels experienced in idling percussive tools may cause transducer problems like zero-shift or breakdown. These errors may be eliminated using proper transducer adaptation techniques.

On transducer application the following is quoted from the draft proposal ISO/DIS 5349:

“The vibration pick-up must be small and light enough for the specific application. Its cross-axis sensitivity must be at least 20 dB below the sensitivity in the axis to be measured.

The measurements in the three axes shall be made at, or clearly related to, the surface of the hand where the energy enters the body. If the

hand of the person is in direct contact with the vibrating surface of the hand grip, the transducer should be fastened to the vibrating structure. If a resilient element is being used between the hand and the vibrating structure (for example, a cushioned handle), it is permissible to use a suitable mount for the transducer (for example, a thin, suitably formed metal sheet) placed between the hand and the surface of the resilient material. In either case, care must be taken that the size, shape and mounting of the transducer or of the special transducer support do not significantly influence the transfer of vibration to the hand. Care must be taken when mounting the transducer that the transfer function is flat up to 1500 Hz for all three directions.

Notes:

1. For signals with a very high crest factor, for example those obtained from percussive tools, special precautions must be taken to avoid overloading any part of the system. Correct choice of the transducer is essential in this case. It may be possible to use a mechanical filter with a suitable calibrated linear transfer function to reduce the crest factor of these signals.
2. The proposed method for the case of a resilient element between the hand and the vibrating structure is not satisfactory for all conditions, particularly in the case of thin cushions mainly affecting the transfer of higher frequencies. In such cases it might be preferable to make the measurements with the transducer rigidly attached to the handle or structure and to report separately the type, thickness, physical properties and estimated attenuation achieved by the cushioning material.

Although characterization of the vibration exposure currently uses the acceleration (velocity) transmitted to the hand as the primary quantity, it is reasonable to assume that the biological effects might depend to a large extent on the energy transmitted. This energy depends on the coupling of the hand-arm system to the vibration source and consequently on the grip pressure applied and the magnitude and direction of the static force. Measurement of the energy transmitted to the hand and of the tool application force is feasible and desirable for research purposes and for future application to special tools, but is not yet proposed in this International Standard. For the purpose of this International Standard, the vibration exposures shall be reported for a grip pressure and static force representative of the operational application of the tool or coupling of the hand to the vibrating machinery. It must be realized that changes in coupling can affect considerably the vibration exposure measured.”.

- In order to meet the requirements a special handle has been developed at Brüel & Kjær. It has been important to consider the following points:
- The frequency response of the adaptor should be linear from 5 Hz to above 1200 Hz.
  - The adaptor must represent a minimum load to the hand.
  - It should be easily adaptable and measure as close as possible to the standardized reference point on both right and left hand.
  - It should realistically reflect the used grip strength.
  - It shall never underestimate the energy transmitted to the hand from the handle.

An adaptor has been developed which covers these requirements and has been tested in various practical situations. The adaptor represents a compromise between close coupling to the handle of the work piece and close coupling to the hand.

To be on the safe side in protecting the hand, the adaptor is designed to measure more closely the vibration of the handle than that experienced on the hand itself, if any difference exists. A drawing giving main dimensions is shown in Fig. 19.




Fig. 19: Hand adaptor manufactured in lightweight metal, magnesium or aluminium alloy




Fig. 20. Transfer function from handle to hand adaptor  
 - - - vibration level of handle  
 ——— vibration level of hand

In Fig. 20 the response of a special vibrator with a test handle with built-in accelerometer is shown. The spectrum is equalized between 12 and 1200 Hz for a flat pink noise spectrum on the handle. The output from the adaptor applied by normal hand pressure is shown for the x direction. The transfer function, handle to adaptor, can thus be measured. The increase in level between 500 to 1000 Hz is caused by the compliance of the hand combined with the stiffness of the adaptor and the application force. The adaptor seems thus to overestimate the vibration level fed to the hand around 1000 Hz. However, a practical test on a pneumatic tool indicates an underestimation in relation to the usual reference point for pneumatic tools. In this case it is safe to assume that the adaptor gives a more realistic value than the reference accelerometer mounted on a mechanical filter on a welded stud in front of the handle.




Fig. 21. Vibration level on third metacarpal, on wrist and elbow for flat pink noise spectrum on handle as shown in Fig.20.

For comparison is shown the transfer function from the handle to the head of the third metacarpal, which is the standardized coordinate system reference position for the hand. (See Fig. 21).

The transfer function to the wrist (Fig. 21) and to the elbow is also shown.

Use of the proposed adaptor for hand-arm measurements is thus believed to be very safe, convenient, and to give reproducible results. Fig. 22 shows photographs of the actual test set-up for obtaining the hand-arm vibration responses shown in Figs. 20 and 21.

Fig. 23 shows the performance of the adaptor under standardized response test conditions for acceleration pick-ups mounted on 180 gr. of stainless steel.





Fig. 22. Test set-up for transfer function measurements



Adaptor with 4375 accelerometer in z direction

811490

Fig. 23. Frequency response of the adaptor on a 180 g stainless steel block




Fig. 24. PNEUROP chip hammer measurements comparing  
 ---- welded stud mounting versus  
 —— hand adaptor measurements





Fig. 25. PNEUROP chiphammer



Fig. 24 shows comparison of results measured on a PNEUROP round robin chip hammer shaving a 2 mm chip. The dotted line shows levels measured on a welded stud on the handle as shown in Fig.25, using a mechanical filter B & K UA 0559 and an accelerometer B & K Type 4369, while the full line shows the levels measured on the hand adaptor. The increase in level at low frequencies (8 —31,5 Hz) for the stud-mounted accelerometer is caused by noise.




*Fig. 26. PNEUROP chiphammer measurements using overall weighting  $L_{eq}$  and Peak, calculating the exposure over a measured elapsed time*

### **Acknowledgements**

The author wishes to thank Mr.J.R.Hassall for writing the introduction and the section on vibration exposure criteria.

## News from the Factory

### Universal Balancing Machine Type 3906




The B & K range of equipment for balancing rotating machine parts has been extended by the addition of a Universal Balancing Machine, Type 3906, for dynamic balancing of work pieces up to 50 kg. It is suitable for balancing fans, armatures, automotive parts and all kinds of rotors down to balance quality grades G1 and Q1 as defined for static unbalance in ISO 1940 and VDI 2060 respectively.

The 3906, like the smaller Type 3905, is designed to be used with the Balancing Machine Console Type 2504, which calculates the corrections required to bring the rotor into balance. The 3906 features a substantial cast-iron bed, incorporating machined ways, soft-bearing suspension, and end-drive of the work piece by a two-speed 3-phase induction motor via a cardan shaft. Sensing of vibration due to unbalance is performed by piezoelectric accelerometers embedded in the bearing supports, and the outputs of these accelerometers are amplified by charge preamplifiers fitted in the bearing support posts. Rotors may be spun for balancing in either direction, at 750 or 1500 r/min on 50 Hz supplies, and 900 or 1800 r/min on 60 Hz supplies.

The 3906/2504 system incorporates electronic compensators for ease of calibration, an angle reference generator for making corrections quickly and unambiguously, memory for holding the unbalance displays after the rotor has stopped turning, and a number of safety features to protect the operator. The displays are of the LED type, and provision is made to display either bearing vibration velocity (for comparison with the required balance quality grade), or required correction in practical correction units, without interfering with the calibration. The operator can control the Balancing Machine motor from the Console, and can set it to shut down automatically when the displays of unbalance have become steady.

### **Precision Sound Level Meter Type 2232**



The Precision Sound Level Meter Type 2232 is an economical slim-line instrument that complies with IEC 651 Type 1, DIN 45 633, Part 1, BS 5969 Type 1 and ANSI S 1.4 Type S 1A standards.


Its large digital display, which is automatically updated every second, gives a single value indication of the maximum A-weighted RMS sound pressure level occurring in the previous second. The display can also be updated manually, allowing the maximum level occurring during a noise event, such as traffic pass-bys, to be held and displayed.

The measurement range of 34 to 130 dB(A) is divided into two display sub-ranges 34–94 dB(A) and 70–130 dB(A), which eliminates the need for switching between them in most measurement situations. For fluctuating noises, the instantaneous RMS value can be continuously recorded on the Portable Level Recorder Type 2306 via the DC output incorporated in the 2232. “Underrange”, “Overload” and “Battery Low”

warnings are automatically indicated. The instrument is powered by two 9 V alkaline batteries giving approximately 30 hours of continuous operation.

The 2232 will find its uses in the field of community and industrial noise surveys, traffic noise measurements and checking compliance with noise rating recommendations.

### **Prepolarized Condenser Microphone Type 4176**



The B & K 1/2-inch Prepolarized Condenser Microphone Type 4176 is a free-field microphone designed for use with B & K Sound Level Meters and other sound measuring systems. It satisfies the microphone requirements for sound measurements made according to IEC 651 Type 1 and when used with the Random Incidence Corrector DZ 9566 it satisfies ANSI S1.4 Type 1 and the proposed revision of this standard.


The charge carrying layer is deposited on the backplate as is the case with other B & K prepolarized condenser microphones. This has helped produce as high a stability (rate of change of sensitivity) and as low a temperature coefficient as that of the externally polarized B & K microphones. For example, due to artificial ageing an excellent long term stability of less than 1 dB in 250 years has been achieved for a temperature of 20°C.

The microphone has an external grid, protecting the diaphragm, as an integral part of the microphone casing thus making it more robust. This grid has an internal gauze filter as protection against dust ingress.

Static pressure equalization between the internal cavity and the atmosphere takes place at the rear of the microphone cartridge via a vent whose size defines the lower limiting frequency. Rear venting allows the Dehumidifier UA 0308 to be fitted directly onto the microphone. This holds the cartridge interior dry to ensure optimum performance in particularly humid environments.

The Type 4176 has a free-field frequency range of 5 Hz to 12,5 kHz with an upper limit to its dynamic range of 142 dB SPL. The typical open circuit sensitivity given at 250 Hz is  $-26$  dB (50 mV/Pa) re. 1 V/Pa, however, each microphone is delivered with a calibration chart showing the individual sensitivity of the microphone and the typical frequency response.

### **High Sensitivity General Purpose Accelerometer Type 4381**



4381 is a Uni-Gain® general purpose accelerometer which has a relatively high sensitivity of  $10 \text{ pC/ms}^{-2} (\pm 2\%)$ . It is optimized to have excellent all-round specifications and is applicable to a wide variety of vibration measurements in the laboratory, in industry and in education.

The accelerometer weighs 43 grams, has a side mounted connector and has a frequency range which is linear to within 10% between 0,2 and 6000 Hz. The use of Delta Shear® design gives extremely low sensitivity to temperature transients ( $0,08 \text{ ms}^{-2}/^{\circ}\text{C}$ ) and to base strains ( $0,003 \text{ ms}^{-2}/\mu\epsilon$ ).

## **PREVIOUSLY ISSUED NUMBERS OF BRÜEL & KJÆR TECHNICAL REVIEW**

*(Continued from cover page 2)*

- 4-1976 An Easy and Accurate Method of Sound Power Measurements.  
Measurement of Sound Absorption of rooms using a Reference  
Sound Source.
- 3-1976 Registration of Voice Quality.  
Acoustic Response Measurements and Standards for Motion-  
Picture Theatres.
- 2-1976 Free-Field Response of Sound Level Meters.  
High Frequency Testing of Gramophone Cartridges using an  
Accelerometer.
- 1-1976 Do We Measure Damaging Noise Correctly?
- 4-1975 On the Measurement of Frequency Response Functions.
- 3-1975 On the Averaging Time of RMS Measurements (continuation)
- 2-1975 On the Averaging Time of RMS Measurements.  
Averaging Time of Level Recorder Type 2306 and "Fast" and  
"Slow" Response of Level Recorders 2305/06/07.

















### **SPECIAL TECHNICAL LITERATURE**

As shown on the back cover page, Brüel & Kjær publish a variety of technical literature which can be obtained from your local B & K representative.

The following literature is presently available:

- Mechanical Vibration and Shock Measurements  
(English), 2nd edition
- Acoustic Noise Measurements (English), 3rd edition
- Acoustic Noise Measurements (Russian), 2nd edition
- Architectural Acoustics (English)
- Strain Measurements (English, German, Russian)
- Frequency Analysis (English)
- Electroacoustic Measurements (English, German, French, Spanish)
- Catalogs (several languages)
- Product Data Sheets (English, German, French, Russian)

Furthermore, back copies of the Technical Review can be supplied as shown in the list above. Older issues may be obtained provided they are still in stock.



1-050 0002-2A

**Brüel & Kjær**

DK-2850 NÆRUM, DENMARK · Telephone: + 45 2 80 05 00 · Telex: 37316 bruka dk